

MidAmerican Energy Co., Council Bluffs

	CEMS Values				
	SO₂ Tons	NO_x lb/mmBtu	NO_x Tons	CO lbs/mmBtu	
EP001	1,163.1	0.463	1023.95	0.745	*Pre LNB Value
EP002	1,877.0	0.412	1448.57	0.309	
EP003	15,294.6	0.423	12042.41	0.187	

Note: NO_x Tons = (Sum of Hourly (NOX lb/mmBtu x Heat lbs/mmBtu))/2000