

MidAmerican Energy Co., Council Bluffs

	CEMS Values				
	SO₂ Tons	NO_x lb/mmBtu	NO_x Tons	HI mmBtu	CO lbs/mmBtu
EP001	1,389.5	0.347	815.00	4,685,202	0.503
EP002	1,993.8	0.431	1364.50	6,281,538	0.419
EP003	14,139.3	0.363	8617.20	45,431,195	0.170

Note: NO_x Tons = (Sum of Hourly (NOX lb/mmBtu x Heat lbs/mmBtu))/2000