

**Response of  
Interstate Power and Light Company  
to  
OFFICE OF CONSUMER ADVOCATE  
Data Request No. 30**

Docket Number: EEP-08-1  
Date of Request: July 2, 2008  
Response Due: July 10, 2008  
Information Requested By: Jennifer Easler  
Date Responded: July 10, 2008  
Author: Lisa Pucelik  
Author's Title: Product Manager  
Author's Telephone No.: (319) 786-4283  
Subject: Residential Rebate Program

---

**Data Request No. 30**

Why are EER ratings not specified for <65,000 Btu central air-conditioning and air-source heat pumps?

**Response**

The 2006 IECC standard for air-source heat pumps and central air conditioning is based on SEER rating, not EER, for <65,000 Btu. HVAC equipment of this capacity is typically available with SEER, rather than EER, ratings.