

**Response of  
Interstate Power and Light Company  
to  
OFFICE OF CONSUMER ADVOCATE  
Data Request No. 79**

Docket Number: EEP-08-1  
Date of Request: July 3, 2008  
Response Due: July 11, 2008  
Information Requested By: Jennifer Easler  
Date Responded: July 17, 2008  
Author: Gilbert Nunez  
Author's Title: Product Manager  
Author's Telephone No.: (319) 786-7237  
Subject: Custom Rebates – CHP Program Component

---

**Data Request No. 79**

IPL states that “Incentives will be available for CHP implementation only after all energy efficiency measures have been implemented by the building owner.”

- A. What is the standard for “all energy efficiency measures?”
- B. How will it be verified?
- C. Will the IPL provide incentives for this work?

**Response**

- A. IPL objects to OCA data request 79, part A as vague and ambiguous. IPL understands the question to ask by what standards will the energy efficiency measures be judged. Without waiving its objection, IPL states the following:

The standard for all identified energy efficiency measures will be the State of Iowa Energy code ASHRAE 90.1 2004.

- B. A study of the facility will be conducted to ensure all energy efficiency measures are verified at meeting State of Iowa Energy code before a customer is eligible for CHP incentives.
- C. IPL customers will be eligible for incentives under the Nonresidential Energy Efficiency Portfolio.